

DRINKING WATER NOTICE

St. Clairsville, City Of PWS Has Levels of Total Haloacetic Acids (HAA5) above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for Total Haloacetic Acids (HAA5). The average level of Total Haloacetic Acids (HAA5) over the last four quarters was 0.065 mg/L. The standard for Total Haloacetic Acids (HAA5) is 0.060 mg/L.

What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the following necessary steps:

- More frequent tank turnover
- Increased system flushing frequency
- Increased powdered activated carbon dosage _____ to correct the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: Jeff Muttler

Phone Number: (740) 695-1161

Mailing Address: 140 Reservoir Rd
St. Clairsville OH 43950

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: 2.12.24

PWSID: OH0701516 Facility ID: DS1

Monitoring Period: First Quarter of 2024